

From: jmaz@driggsidaho.org
To: [Lopez, Maria](#)
Subject: RE: CWA-10-2018-0206
Date: Thursday, June 10, 2021 9:02:27 AM
Attachments: [Driggs WRF FPS 4-1-2020.pdf](#)

Maria,

Attached is the draft FPS. We have not approved/adopted it, as it is under review. We completed the cleaning of the East Treatment Train in late May and have brought it back on line. The effluent quality is night and day versus the west treatment train. In-house testing on Monday showed the East Treatment Train (just cleaned) was in full compliance for ammonia! The cleaning process took approximately 7 weeks at a cost of \$150,000 (\$80,000 contractor, \$70,000 city staff and equipment). We are trying to determine when to clean the West Treatment Train as we can only do it when our flows are low. If you need any additional information or a formal update, do not hesitate to call or email.

Thank you,

Jay

Jay T. Mazalewski, PE

Director of Public Works

City of Driggs, Idaho | *The Heart of Teton Valley*

PO Box 48 | 60 S Main St | Driggs, ID 83422

Ph 208.354.2362 ext 2115 Fax 208.354.8522

www.driggsidaho.org

www.facebook.com/Driggsidaho

From: Lopez, Maria <Lopez.Maria@epa.gov>

Sent: Thursday, June 10, 2021 9:36 AM

To: jmaz@driggsidaho.org

Subject: RE: CWA-10-2018-0206

Hi Jay,

First of all, thank-you for providing the April 09,2021 update. In reviewing the information provided, I noticed we do not have a copy of the City's most recent Facility Plan that you mentioned in the letter. Is this something you can send me? If the file is too large, I can provide a link to our FTP site. If you have any questions on this request, feel free to contact me.

Thank-you,

Maria Lopez

EPA IOO Region 10

(208) 378-5616

From: jmaz@driggsidaho.org <jmaz@driggsidaho.org>

Sent: Friday, April 09, 2021 12:26 PM

To: Lopez, Maria <Lopez.Maria@epa.gov>

Cc: 'Mayor Johnson' <mayorjohnson@driggsidaho.org>

Subject: CWA-10-2018-0206

Maria,

Please find the attached update. If you have any question or need additional information, please call or email.

-Jay

Jay T. Mazalewski, PE

Director of Public Works

City of Driggs, Idaho | *The Heart of Teton Valley*

PO Box 48 | 60 S Main St | Driggs, ID 83422

Ph 208.354.2362 ext 2115 Fax 208.354.8522

www.driggsidaho.org

www.facebook.com/DriggsIdaho

****All communications are subject to Idaho Open Records Law and Driggs City Communications Policies.**

****All communications are subject to Idaho Open Records Law and Driggs City Communications Policies.**